

Aquarion Water Company PFAS Sampling Results

Town/City: New Milford / Brookfield
Water System Name: Park Glen

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Park Glen Wells, POE	May 2019	ND		ND		ND		ND	
	Jun. 2021	ND		ND		ND		ND	
	Oct. 2022	ND	16	ND	10	ND	49	ND	12

Footnotes:

* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022.

Definitions:

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.