

## Aquarion Water Company PFAS Sampling Results

**Town/City: Ridgefield**

**Water System Name: Ridgefield Main**

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Branchville Pump Station, Distribution Point	Jun. 2019	3		ND		ND		ND	
Beechwood Wells, POE	Jun. 2019	12		ND		ND		ND	
	Aug. 2019	6		ND		ND		ND	
	Jun. 2020	9		ND		ND		ND	
	Aug. 2020	5		2		ND		ND	
	Oct. 2020	4		ND		ND		ND	
	Feb. 2021	5		ND		ND		ND	
	Jun. 2021	5		ND		ND		ND	
	Aug. 2021	5		ND		ND		ND	
	May 2022	2		ND		ND		ND	
	Sep. 2022	5	16	ND	10	ND	49	ND	12
North St Wells, POE	Jun. 2019	4		5		ND		ND	
	Jun. 2021	4		4		ND		ND	
	Jul. 2021	3		4		ND		ND	
	Sep. 2022	5	16	5	10	ND	49	ND	12
Oscaleta Wells, POE	Jun. 2019	5		ND		ND		ND	
	Jun. 2021	4		ND		ND		ND	
	Aug. 2021	5		3		ND		ND	
	Sep. 2022	3	16	ND	10	ND	49	ND	12

**Footnotes:**

\* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022.

**Definitions:**

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.