

Non Revenue Water - 12 Months Rolling Average												
	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Dec-16
Darien	9.3%	9.5%	9.0%	9.2%	8.0%	9.7%	9.7%	9.4%	6.4%	6.3%	7.0%	6.4%
Greenwich	17.8%	18.1%	18.3%	18.7%	18.4%	19.8%	19.4%	18.7%	18.3%	18.5%	19.5%	19.4%
New Canaan	22.1%	21.5%	20.6%	20.1%	18.7%	18.3%	16.2%	13.6%	11.1%	10.5%	9.8%	8.6%
Stamford	13.2%	13.0%	12.6%	12.2%	12.1%	13.3%	13.3%	13.2%	13.9%	14.2%	14.4%	14.0%

*New Canaan Note: 8.6MG leak found 10/6, 0.72 MG leak found 11/2. Little Brook Pump station was over-registering 22.5%. Adjustments were made back to Jan 1*