

Monitoring Results for Water Supply Emergency Amended Order

Quality of Distribution Water in Greenwich

ND = not detected

Weekly Samples

	Water Quality Standards mg/L	6.4 - 10.0	4.00	NA	NA	15	5	2	12	12	0 /100 ml	500 cfu/m L
Greenwich	Date	pH	CL2	Temperature	Conductivity	Color	Turbidity	Odor	O PO4	T PO4	MFTC	HPC
Round Hill Rd SS	3/6/2017	7.6	0.80	7.2	400.0	2	0.10	0	1.09	1.03	0	--
Glenville MS SS	3/6/2017	7.6	0.51	7.3	410.0	1	0.10	0	1.03	0.97	0	--
2 Lincoln Ave SS	3/6/2017	7.6	1.05	8.2	479.0	3	0.35	1	1.04	1.00	0	--
No. Mianus School SS	3/6/2017	7.5	1.67	4.1	478.0	1	0.10	0	1.08	0.97	0	--

Greenwich	Date	pH	CL2	Temperature	Conductivity	Color	Turbidity	Odor	O PO4	T PO4	MFTC	HPC
Round Hill Rd SS	3/13/2017	7.6	0.80	7.0	399.0	1	0.10	0	1.03	1.01	0	--
Glenville MS SS	3/13/2017	7.5	0.61	7.2	400.0	1	0.10	0	0.99	0.94	0	--
2 Lincoln Ave SS	3/13/2017	7.4	0.91	8.1	487.0	2	0.20	0	0.95	0.93	0	--
No. Mianus School SS	3/13/2017	7.3	1.01	3.7	486.0	1	0.05	0	0.99	0.98	0	--

Greenwich	Date	pH	CL2	Temperature	Conductivity	Color	Turbidity	Odor	O PO4	T PO4	MFTC	HPC
Round Hill Rd SS	3/20/2017	7.4	0.69	7.6	405.0	1	0.10	0	1.24	1.07	0	--
Glenville MS SS	3/20/2017	7.3	0.66	6.7	439.0	1	0.10	0	1.08	0.97	0	--
2 Lincoln Ave SS	3/20/2017	7.3	0.90	7.2	529.0	2	0.25	0	1.08	0.99	0	--
No. Mianus School SS	3/20/2017	7.3	1.30	5.7	512.0	1	0.05	0	1.09	1.07	0	--

Greenwich	Date	pH	CL2	Temperature	Conductivity	Color	Turbidity	Odor	O PO4	T PO4	MFTC	HPC
Round Hill Rd SS	3/27/2017	7.4	0.73	6.3	411.0	2	0.10	0	pending	pending	0	--
Glenville MS SS	3/27/2017	7.4	0.58	6.5	412.0	2	0.10	0	pending	pending	0	--
2 Lincoln Ave SS	3/27/2017	7.2	0.99	7.6	490.0	3	0.40	0	pending	pending	0	--
No. Mianus School SS	3/27/2017	7.1	1.17	5.9	488.0	1	0.10	0	pending	pending	0	--