

**Monitoring Results for Water Supply Emergency Order**

**Quality of Untreated Water Entering Putnam Water Treatment Plant**

ND = not detected

**Inorganics**

Secondary Standards

Raw Water Quality Standards mg/L	0.01	1	0.01	250	0.05	1	0.2	2	0.05	0.5	0.005	10	1	0.01	0.05	NA	NA
Date	Arsenic	Barium	Cadmium	Chloride	Chromium	Copper	Cyanide	Fluoride	Lead	MBAS	Mercury	Nitrate	Nitrite	Selenium	Silver	Iron	Manganese
9/30/2016	ND	0.037	ND	64.0	ND	ND	ND	0.05	ND	ND	ND	0.031	ND	ND	ND	NA	NA
11/1/2016	ND	0.042	ND	65.0	ND	ND	ND	0.07	ND	ND	ND	0.062	ND	ND	ND	0.35	0.21
12/5/2016	ND	0.039	ND	59.0	ND	ND	ND	0.07	ND	ND	ND	0.063	ND	ND	ND	0.20	0.07
1/2/2017	ND	0.038	ND	60.0	ND	ND	ND	0.06	ND	ND	ND	0.082	ND	ND	ND	0.09	0.06
2/1/2017	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending

**Pesticides**

Raw Water Quality Standards mg/L	0.002	0.0002	0.040	0.003	0.070	0.050
Date	Endrin	Lindane	Methoxychlor	Toxaphene	2,4-D	2,4,5-TP (silvex)
9/30/2016	ND	ND	ND	ND	ND	ND
11/1/2016	ND	ND	ND	ND	ND	ND
12/5/2016	ND	ND	ND	ND	ND	ND
1/2/2017	Discontinued					