

Monitoring Results for Water Supply Emergency Order

Quality of Untreated Water Entering Stamford Water Treatment Plant

ND = not detected

Inorganics

Secondary Standards

Raw Water Quality Standards mg/L	0.01	1	0.01	250	0.05	1	0.2	2	0.05	0.5	0.005	10	1	0.01	0.05	NA	NA
Date	Arsenic	Barium	Cadmium	Chloride	Chromium	Copper	Cyanide	Fluoride	Lead	MBAS	Mercury	Nitrate	Nitrite	Selenium	Silver	Iron	Manganese
9/30/2016	ND	0.021	ND	53.0	ND	ND	ND	0.05	ND	ND	ND	0.046	ND	ND	ND	NA	NA
11/1/2016	ND	0.025	ND	58.0	ND	ND	ND	0.05	ND	ND	ND	0.044	ND	ND	ND	0.28	0.11
12/5/2016	ND	0.023	ND	51.0	ND	ND	ND	0.06	ND	ND	ND	0.003	ND	ND	ND	0.30	0.10
1/2/2017	ND	0.026	ND	56.0	ND	ND	ND	0.05	ND	ND	ND	0.186	ND	ND	ND	0.46	0.20
2/1/2017	ND	0.021	ND	53.0	ND	ND	ND	0.04	ND	ND	ND	0.062	ND	ND	ND	0.12	0.03
3/1/2017	ND	0.022	ND	58.0	ND	ND	ND	0.04	ND	ND	ND	0.075	ND	ND	ND	0.09	0.02

Pesticides

Raw Water Quality Standards mg/L	0.002	0.0002	0.040	0.003	0.070	0.050
Date	Endrin	Lindane	Methoxychlor	Toxaphene	2,4-D	2,4,5-TP (silvex)
9/30/2016	ND	ND	ND	ND	ND	ND
11/1/2016	ND	ND	ND	ND	ND	ND
12/5/2016	ND	ND	ND	ND	ND	ND
1/2/2017	Discontinued					
2/1/2017	Discontinued					
3/1/2017	Discontinued					