Monitoring Results for Water Supply Emergency Order

Quality of Untreated Water Entering Stamford Water Treatment Plant

ND = not detected

Quality	250 CU	250 NTU	20000/100ml	1 ug/L	1 ug/L	NA	NA	NA
Date	**Color**	**Turb**	**Total Coliform**	**Microcystin**	**Cylindrospermopsin**	**Alkalinity**	**TOC**	**T PHOS**
12/19/2016	39	3.0	135	Discontinued	Discontinued	44	3.24	0.10
12/27/2016	45	2.9	41	Discontinued	Discontinued	42	3.08	0.06
1/2/2017	44	2.9	55	Discontinued	Discontinued	40	3.10	0.06
1/9/2017	38	3.1	32	Discontinued	Discontinued	46	3.10	0.08
1/17/2017	38	2.6	32	Discontinued	Discontinued	49	3.01	0.07
1/23/2017	25	2.0	22	Discontinued	Discontinued	50	3.15	0.06
1/30/2017	25	2.1	56	Discontinued	Discontinued	46	3.21	0.09
2/6/2017	44	2.6	141	Discontinued	Discontinued	35	3.23	0.09
2/13/2017	29	2.5	12	Discontinued	Discontinued	44	3.88	0.07
2/21/2017	22	1.4	16	Discontinued	Discontinued	44	3.66	0.07
3/1/2017	28	1.7	39	Discontinued	Discontinued	43	2.96	0.05
3/7/2017	28	1.6	30	Discontinued	Discontinued	43	3.03	0.06
3/13/2017	23	1.6	24	Discontinued	Discontinued	41	3.09	0.06
3/20/2017	23	1.6	12	Discontinued	Discontinued	pending	3.10	0.06
3/27/2017	Discontinued by order		Discontinued	Discontinued	Discontinued	Discontinued	Discontinued	Discontinued