

## Monitoring Results for Water Supply Emergency Ammended Order

NA = not applicable

### Quality of Distribution Water in Stamford at Iliff Pump Station

ND = not detected

#### Weekly Samples

	Water Quality Standards mg/L	6.4 - 10.0	4.00	NA	NA	15	5.00	2	12	12.00	0 /100 ml	500 cfu/mL
Stamford	Date	pH	CL2	Temperature °C	Conductivity	Color	Turbidity	Odor	O PO4	T PO4	MFTC	HPC
Iliff PS	10/21/2016	8.2	0.18	17.1	388.0	10	1.30	0	0.40	1.16	0	2
Iliff PS	10/25/2016	7.4	0.58	13.3	347.0	1	0.10	0	1.10	0.96	0	0
Iliff PS	10/31/016	7.3	0.56	14.0	247.0	3	0.20	0	1.00	0.94	0	0
Iliff PS	11/7/2016	7.3	0.66	14.0	271.0	1	0.10	2	1	0.94	0	NA
Iliff PS	11/10/2016	7.3	0.69	13.7	251.0	1	0.10	0	NA	NA	0	0
Iliff PS	11/14/2016	7.3	0.61	13.9	246.0	1	0.15	0	1.10	0.95	0	0
Iliff PS	11/21/2016	7.4	0.71	11.6	267.0	1	0.10	0	1.10	0.92	0	0
Iliff PS	11/28/2016	7.3	0.79	11.9	270.0	2	0.10	0	1.00	0.92	0	0
Iliff PS	12/5/2016	7.4	0.78	7.0	293.0	1	0.10	0	1	0.95	0	0
Iliff PS	12/12/2016	7.3	0.81	8.9	258.0	1	0.10	0	pending	pending	0	0