Monitoring Results for Water Supply Emergency Amended Order

NA = not applicable

ND = not detected

Quality of Distribution Water in Stamford at Iliff Pump Station

Weekly Samples

	Water Quality Standards mg/L	6.4 - 10.0	4.00	NA	NA	15	5.00	2	12	12.00	0 /100 ml	500 cfu/mL	NA	250	NA
Stamford	Date	pH	CL2	Temperature °C	Conductivity	Color	Turbidity	Odor	O PO4	T PO4	MFTC	HPC	ALK	Chloride	Sulfate
Iliff PS	1/2/2017	7.4	0.74	6.5	251.0	1	0.10	0	1.00	0.89	0	0	44	35	15.8
Iliff PS	1/9/2017	7.4	1.37	3.9	259.0	2	0.20	0	1.10	1.00	0	0	46	36	15.4
Iliff PS	1/17/2017	7.4	0.84	7.1	268.0	2	0.10	0	0.96	0.91	0	1	46	37	15.5
Iliff PS	1/23/2017	7.4	0.71	7.0	260.0	1	0.10	0	0.96	0.92	0	0	44	36	16.2
Iliff PS	1/30/2017	7.3	0.83	7.5	276.0	1	0.10	0	0.81	0.95	0	0	44	38	15.4
Iliff PS	2/10/2017	7.4	0.82	6.0	274.0	1	0.10	0	1.00	0.98	0	0	45	39	15.1
Iliff PS	2/13/2017	7.2	0.85	6.8	267.0	1	0.10	0	1.00	0.99	0	0	45	37	15.3
Iliff PS	2/21/2017	7.4	0.77	6.5	247.0	2	0	0	1.10	0.96	0	0	36	37	17.3
Iliff PS	3/1/2017	7.5	0.67	9.7	248.0	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending