Monitoring Results for Water Supply Emergency Amended Order

NA = not applicable

ND = not detected

Quality of Distribution Water in Stamford at SWRP Additional Temporary Pipeline Terminus

Weekly Samples

	Water Quality Standards mg/L	6.4 - 10.0	4.00	NA	NA	15	5.00	2	12	12.00	0 /100 ml	500 cfu/mL	NA	250	NA
Stamford	**Date**	**pH**	**CL2**	**Temperature °C**	**Conductivity**	**Color**	**Turbidity**	**Odor**	**O PO4**	**T PO4**	**MFTC**	**HPC**	**ALK**	**Chloride**	**Sulfate**
SWRP ATP	**1/2/2017**	7.5	0.81	6.7	227.0	1	0.15	0	1.00	0.89	0	0	36	32	32.0
SWRP ATP	**1/9/2017**	7.4	0.98	6.1	259.0	1	0.15	0	1.10	1.00	0	0	45	36	15.2
SWRP ATP	**1/17/2017**	7.6	0.75	6.5	256.0	1	0.15	0	0.91	0.87	0	0	43	35	15.8
SWRP ATP	**1/23/2017**	7.5	0.83	6.8	248.0	1	0.10	0	0.96	0.90	0	0	43	34	16.4
SWRP ATP	**1/30/2017**	7.3	0.88	7.1	254.0	2	0.15	0	0.93	0.94	0	0	41	35	15.8
SWRP ATP	**2/10/2017**	7.5	0.86	6.7	257.0	2	0.10	0	0.99	0.91	0	0	44	36	15.2
SWRP ATP	**2/13/2017**	7.1	0.71	6.9	261.0	1	0.10	0	0.91	0.96	0	0	44	36	15.4
SWRP ATP	**2/21/2017**	7.4	0.81	6.1	242.0	1	0	0	1	1	0	0	36	36	17.2
SWRP ATP	**3/1/2017**	7.6	0.77	8.3	229.0	pending	pending	pending	pending	pending	pending	pending	pending	pending	pending